



PRI1 DIMENSIONS

| | | | |
|--|---------|----------------------------|---------|
| Concept systems | | Concept Systems Inc | |
| | | 1957 Fescue STSE (MFG) | |
| | | Albany, OR 97322 | |
| | | (541) 791-8140 | |
| Enclosed Industrial Control Panel | | | |
| (Company) | | SN: | CE1 |
| Manufacture Date: | TBD | | |
| Order Number: | TBD | | |
| Supply Voltage: | 480VAC | Frequency: | 60 HZ |
| FLA: | 4A | Phases: | 3 |
| Interrupt/SCCR: | 100kA | Largest Motor FLA: | n/a |
| Enclosure Rating: | TYPE 12 | | |
| For use with UL type 12 Conduit Fittings | | | |
| SHOP DEFINED UL SERIAL # | | | UL-508A |
| Ref. Drawing No.: | PD-110 | | |